



TYPICAL ELEVATION

TYPICAL 2 STOP HOISTWAY LAYOUT

RESIDENTIAL ELEVATORS (REI) CONTROL SYSTEM CONTAINS THE 240 VAC AND 120 VAC DISCONNECTS, HOWEVER; GC/ OWNER MUST PROVIDE DEDICATED CIRCUIT AND WIRE TO 4" x 4" BOX (1 FOR 240 VAC & 1 FOR 120 VAC) IN MACHINE SPACE PER DRAWING. SEE REI ELECTRICAL REQUIREMENTS BROCHURE FOR FURTHER DETAILS.

NOTES:

1. RAIL IS CONCRETE ANCHORED WITH 1/2" REDHEAD OR CONCRETE SLEEVE BOLTS GR.5 - 1/2" x 4" ANCHORS
2. RAIL BRACKETS ARE LAGGED WITH 1/2" x 4" HEX HEAD LAG SCREWS
3. FOR EACH 1" HOISTWAY IS REDUCED IN WIDTH OR DEPTH CAR SIZE IS REDUCED BY 1" IN WIDTH OR DEPTH

THE INFORMATION CONTAINED HEREIN IS SOLELY OWNED BY RESIDENTIAL ELEVATORS, INC. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT WRITTEN PERMISSION FROM RESIDENTIAL ELEVATORS, INC. IS STRICTLY PROHIBITED.

LUXURY LIFT LLT TRACTION



DRAWN:	CHECKED:	DATE:	REVISION
G.P.	E.S.	03/11/11	REMOVE DISCONNECTS, ADD 4X4 BOXES
G.P.		10/21/09	CHANGE HEIGHT TO STD.
G.P.		06/04/10	ADD LLT DESIGNATION
JOB NAME:			DRAWING NUMBER
TRACTION HOISTWAY ELEVATION (TYP.)			HOR 01